

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


No. F.6 DFS/MS/School/2019/SZ/ 1780

Dated: 17/9/19

**FIRE SAFETY CERTIFICATE**

Certified that the Mount Columbus School located at C-Block, Dakshinpuri, New Delhi-110062 comprised of two blocks-senior block (ground plus two upper floor) and junior block (small basement, ground plus one upper floor) was issued FSC by this department vide letter No. F.6/DFS/MS/School/2016/965 dated 08/06/2016. The said premises was re-inspected by officer concerned of this department on 06/09/2019 in presence of Mr. Rakesh (In charge) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules-2010 and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of **Three years**, subject to compliance of the under mentioned conditions.

Issued on 17/9/19 at New Delhi by



(Rajesh Panwar)  
Dy. Chief Fire Officer  
Tel. 011-26189168

Copy to: -

1. The Principal, Mount Columbus School, C Block, Dakshinpuri, New Delhi-110062.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."